


NOTES:

- 1 Duct entry holes shall be filled with expandable foam.
- 2 Rigid ducts terminating in maintenance holes, handholes, or other permanent openings of underground systems shall be provided with an end bell.
- A For installation details see OPSD 2117.020.
- B All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING	Nov 2017	Rev 0	
ELECTRICAL HANDHOLES			
ENTRY OF DIRECT BURIED AND ENCASED DUCTS			OPSD 2123.030