



DETAIL A

SIDE VIEW

NOTES:

- 1 Cabinet shall be sealed around bottom perimeter with a 10mm thick by 65mm wide neoprene gasket. Gasket shall have a durometer hardness of 45 and shall be provided with adhesive backing for attachment to the cabinet.
- 2 Cabinet shall be secured to the pad, accurately aligned, with chuck end concrete anchors and 16mm dia x 38mm long stainless steel hexagonal head machine bolts and lockwashers. Location of anchors shall be according to manufacturer's instructions.
- A For numbers, sizes, and orientation of conduits entering sleeves in concrete pad, refer to Contract Drawings.
- B For location and orientation of cabinet and concrete pad, refer to Contract Drawings.
- C All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING		Nov 2012	Rev 0	
CONTROLLER CABINET ON PAD		<p style="text-align: center;">OPSD 2514.010</p>		